

EPA 608 Type I from practice test questions and answers rated A

Technicians who perform sealed system service on small appliances must have; ✓✓Type I or universal certification

A small appliance is defined by EPA as; ✓✓Appliances manufactured, charged, and hermetically sealed in a factory with 5 lbs or less of refrigerant

Type I Certification is required for; ✓✓Persons handling refrigerant during maintenance, service, or repair of small appliances.

If regulations change after the technician becomes certified; ✓✓The technician is responsible for complying with any future changes in the regulations.

Recovery equipment manufactured after November 15, 1993 must be; ✓✓Certified by an EPA approved testing laboratory.

Which of the following is true of small appliances refrigerant leaks; ✓✓EPA does not require repair, but leaks should be repaired whenever possible.

Recovery equipment manufactured after November 15, 1993 must be capable of recovering; ✓✓90% of the refrigerant or achieving 5 inches of vacuum.