

## FDNYC G60 Practice Exam Questions and Answers 100% Pass

All torch operators, an oxygen-fuel torch using any amount of oxygen and flammable gas and fire guards must have a current ✓✓Certificate of Fitness

The Certificate of Fitness holder ✓✓must regulate the pressure and flow of oxygen and natural gas to each torch.

if the torch operator for jewelry manufacture involves ✓✓any oxygen with any fuel gas containers, the operator must be a C of F holder.

# learnexams

A Certificate of Fitness Holder must keep his or her certificate ✓✓on their person or otherwise readily available for inspection by any representative of the fire Department

The easiest way to extinguish a fire caused by a leak is to ✓✓close the shutoff valve

Permits issued by the FDNY are required to conduct the following hot work: ✓✓storing, using or handling oxygen and a flammable gas, storing, using or handling any flammable gas (e.g. LPG or CNG or acetylene) in excess of

400 SCF. Storing, using or handling any oxidizing gas (e.g. oxygen) in excess of 504 SCF.

For LPG, 400 SCF is  $\checkmark\checkmark$  approximately 47 lbs

the number of LPG containers for the storage, use, handling or transportation, requiring a permit

$\checkmark\checkmark$  14.1 oz = 54 cont.

16.4 oz = 46 cont.

20 lbs = 3 cont.

33.5 lbs = 2 cont.

40 lbs = 2 cont.

100 lbs = 1 cont.

learnexams

Portable LPG containers that are more than 16.4 oz and CNG containers with a capacity greater than 8.7 SCF  $\checkmark\checkmark$  must NOT stored, handled, or used indoors in the following occupancies (as defined in the Building code): residential occupancies, factory and industrial occupancies; educational occupancies; institutional occupancies, except as the commissioner may authorize by rule.

Site-specific permit ✓✓ may be a permanent permit or a temporary permit. Permanent permits are valid for 12 months only

A city-wide permit is valid ✓✓ up to 30 days

Permits shall be ✓✓ readily available on the premise for inspection by Fire Department representatives.

Hot work authorization should be issued by the responsible person, and it ✓✓ must be available for inspection by any representative of the department during the performance of the work, and for 48 hours after the work is complete

learnexams

FDNY permits ✓✓ will be posted in a central location and recorded in a log book to assist in the coordination of construction related activities.

CNG ✓✓ Compressed Natural Gas.

For Citywide hot work operations, the Owner of the premises must be notified in writing at least \_\_\_\_\_ hours in advance prior to work beginning. ✓✓ 48